

# Williamsburg County Water & Sewer Authority

## 2021 Annual Drinking Water Quality Report

WCWSA

SCDHEC #4510007

### **Introduction**

WCWSA is pleased to present to our customers the Annual Drinking Water Quality Report for State Water System ID #4510007. Our goal is to provide our customers with a safe, high quality, and dependable supply of drinking water. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water for the period of January 1, 2021 to December 31, 2021.

### **Definitions: The following tables contain scientific terms and measures, some of which may require explanation.**

- Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.
- ppm: milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.
- ppb: micrograms per liter or parts per billion – or one ounce in 7,350,000 gallons of water.
- na: not applicable
- ND: Non Detects – laboratory analysis indicates that the constituent is not present

### Test Results of Regulated Contaminants

Lead and Copper	Collection Date	MCLG	Action Level (AL) (ppb)	90 <sup>th</sup> Percentile (ppb)	# Sites Over Action Level	Units	Violation	Likely Source of Contamination
Lead	2021	0	15	1.2	0	ppb	N	Erosion of natural deposits; Corrosion of household plumbing systems.
Copper	2021	1.3	1.3	0.14	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG or MRDLG	MCL, TT, or MRDL	Units	Violation	Likely Source of Contamination
Chlorine	2021	1.2	1.1 - 1.2	4	4	ppm	N	Water additive used to control microbes
Haloacetic Acids (HAAs) (ppb)	2021	7	4.20-12.51	No goal for the total	60	ppb	N	By-product of drinking water chlorination
TTHMs (Total Trihalomethanes) (ppb)	2021	48	16.54– 74.48	No goal for the total	80	ppb	N	By-product of drinking water disinfection
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Fluoride	10/7/2020	1.70	1.40 – 1.70	4	4.0	ppm	N	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Sodium [unregulated]	2020	130 (average)	100 - 160	NA	NA	ppm	N	Erosion of natural deposits
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Gross alpha excluding radon and uranium	11/20/2019	0.452	0.452 – 0.452	0	15	pCi/L	N	Erosion of natural deposits
Combined Radium 226/228	11/20/2019	0.142	0.142 – 0.142	0	5	pCi/L	N	Erosion of natural deposits
Beta/photon emitters	11/20/2019	6.510	4.700 – 6.510	0	50*	pCi/L	N	Decay of natural and man-made deposits
*The MCL for beta particles is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles. Because the beta particle results were below 50 pCi/L, no testing for individual beta particle constituents was required.								

### **Source of Drinking Water**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

### **Water Substance**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

#### **Water Source**

Your water is provided from the four deep groundwater wells listed below.

1. 2522 South Williamsburg County Hwy (G45309)
2. 496 Council Rd (G45310)
3. 120 Keeler Rd (G45340)
4. 2730 Nesmith Rd (G45341)

The public is invited to attend bimonthly County Council Meetings on every 1<sup>st</sup> Monday and 3<sup>rd</sup> Tuesday of each month at 6PM at the Williamsburg County PSA Building, 201 West Main Street, Kingstree, SC 29556.